



**ODISHA PUBLIC SERVICE COMMISSION
CUTTACK**

NO. 1418 /PSC, DATED: 28-02-2018
(IM-9-17-18(STORE))

QUOTATION CALL NOTICE

Sealed quotations are hereby invited from the intending authorised firms/ dealers having valid GST registration along with copies of GST Registration Certificate and PAN card for supply of one 4 nos of UPS of reputed brand of the following specification for use in the office of the Odisha Public Service Commission.

TECHNICAL SPECIFICATION OF UPS

1. Rating- 1 KVA/800W Off line UPS
2. Input Voltage- 160-280V
3. Input Frequency -50Hz
4. Tolerance- 45-55)
5. Surge Protection Device- inbuilt
6. Output rated power -1000VA/800W
7. Output Voltage-220/230V AC
8. LCD display
9. Suitable alarms for battery operation/opverload
10. Backup- minimum for 10 minutes.
11. Warranty- One year onsite OEM Warranty.

The quotation should reach the undersigned by 06-03-2018 by 04.00 PM and the same will be opened at 04.30 PM in my office chamber. The undersigned reserved the right to cancel/ reject any or all the quotations without assigning any reason thereof.

By order of Special Secretary.

F.O-CUM-UNDER SECRETARY.